



MUNICIPALITY *of the*
COUNTY *of* KINGS

Tel: 902-690-6194
Fax: 902-678-9279
squinn@countyofkings.ca

MEMORANDUM

To:	Prospective Bidders NRFP#23-01 Regional STP Cell 1 Desludging	From:	Scott Quinn, P. Eng. Director, EPW Lands and Parks
CC:	Abdelkhalek Omar, P. Eng., Manager of Engineering Services Aaron Dondale, P. Eng., Manager of Public Works		
Subject:	Addendum #1	Date:	January 12, 2023

This Addendum forms part of the “Contract Documents” and modifies or clarifies the original “Contract Documents” for the above referenced procurement call.

1. **Question:** *Can you confirm the volume to remove, stated at 820 m3 Wet Ton. It is Insitu Wet so about 50 Bone Dry Tons to remove or is it dewatered 820 m3 so 175 BDT (820 m3 @ +/-20 %)?*

Response: The estimated volume of sludge to be removed is based on wet in-situ volume.

2. **Question:** *Is it possible to work on 24 hours, 7 days per week basis?*

Response: Yes.

3. **Question:** *Is the transport and disposal of the dewatered cake part of this project? Please confirm*

Response: It is.

4. **Question:** *Is the County of Kings looking for a mechanical method only (via centrifuge) as space is limited or would also accept a passive method (via geotubes) if space is available? Transportation and disposal of dewatered sludge is part of the project.*

Response: The Municipality would accept either a mechanical or passive method.

5. **Question:** *Does the County have analyses of the sludge to determine where the dewatered sludge can be accepted?*

Response: Please refer to the attached CBCL Waste to Energy Feasibility Study for further background and supplemental information. Some of the more applicable sections are as follows:

- Section 1.2.1.4: Sludge Handling

Phone: 902-678-6141 or 1-888-337-2999
Monday - Friday 8:30 a.m. - 4:30 p.m.
inquiry@countyofkings.ca

181 Coldbrook Village Park Drive
Coldbrook, NS B43 1B9
www.countyofkings.ca

- Section 1.3.1: Regional STP Sludge
- Section 3.1: Regional STP Sludge
- Section 6: Sludge Dredging & Dewatering
- Section 7.3: Recommendations regarding dredging and centrifuge dewatering.
- Tables 1-4 (related to Lagoon Sludge only): Appendix A

6. **Question:** *I do not see a price matrix with the RFP, can we do our own to present pricing on the excel spreadsheet?*

Response: Proponents may present the breakdown of their Cost Submission on an Excel spreadsheet using their own matrix provided a PDF version is also provided and that the information specified in the NRFP is clearly presented.

This addendum must be acknowledged in the Submissions.

ALL OTHER SPECIFICATIONS, TERMS AND CONDITIONS REMAIN UNCHANGED.

Phone: 902-678-6141 or 1-888-337-2999
Monday - Friday 8:30 a.m. - 4:30 p.m.
inquiry@countyofkings.ca

181 Coldbrook Village Park Drive
Coldbrook, NS B43 1B9
www.countyofkings.ca